


HR

# BETTER BUILDING PERFORMANCE IN HIGHER EDUCATION

DR JUDIT KIMPIAN  
TAMSIN TWEDDELL  
DR SUNG-MIN HONG  
DR DAVID HAWKINS  
DR ESFAND BURMAN

MAX FORDHAM





#### Specialisms include:

- Architecture
- Building Consultancy
- Advance Design
- Interior Design
- Urban Design & Masterplanning
- Landscape Design



# 5<sup>TH</sup>

LARGEST  
ARCHITECTURAL  
EMPLOYER IN THE  
UNITED KINGDOM

# 45

AHR PROJECTS THAT HAVE  
GAINED A SUSTAINABILITY  
ACCREDITATION, SUCH AS  
BREEAM, LEED, PASSIVHAUS

# 429

EMPLOYERS CURRENTLY  
WORKING IN OVER TWENTY  
COUNTRIES

OVER 13,000  
PROJECTS  
COMPLETED  
ACROSS ALL  
SERVICES  
WITHIN THE  
LAST TEN  
YEARS

# 13

INTERNATIONAL OFFICES  
SERVICING THE REGIONAL  
NEEDS OF EASTERN EUROPE,  
THE MIDDLE EAST, NORTH  
AFRICA AND THE INDIAN SUB  
CONTINENT

# 32m

2014 TURNOVER (GBP)

## AHR OFFICES

### EUROPE

- London
- Birmingham
- Bristol
- Glasgow
- Huddersfield
- Leeds
- Manchester
- Moscow
- Shrewsbury
- Warsaw

### ASIA

- Almaty
- Karachi
- [Associated Office]

### MIDDLE EAST

- Dubai





**1. DUBLIN INSTITUTE OF TECHNOLOGY  
DUBLIN**

**2. UNIVERSITY OF HUDDERSFIELD  
OASTLER BUILDING**

**3. UNIVERSITY OF YORK  
BIO-MEDICINE BUILDING**

**4. UNIVERSITY OF WEST ENGLAND**

**5. FALMOUTH COLLEGE  
TREMOUGH INNOVATION CENTRE**

**6. UNIVERSITY OF BIRMINGHAM  
MASON HALL**

**7. THURROCK LEARNING CAMPUS  
ESSEX, UK**





**1. UNIVERSITY OF LEICESTER**  
SCHOOL OF MUSEUM STUDIES

**2. PLYMOUTH UNIVERSITY**  
POOL INNOVATION CENTRE

**3. UNIVERSITIES OF BATH, BRISTOL  
& THE WEST OF ENGLAND BBSP**  
ONE

**4. UNIVERSITY OF BIRMINGHAM**  
SHACKLETON HALL

**5. UNIVERSITY OF GLASGOW**  
LAB REFURBISHMENT TO BOYD  
ORR BUILDING


**6. THURROCK LEARNING CAMPUS**  
ESSEX, UK

**7. CONNELL COLLEGE**  
MANCHESTER, UK







1. **MASDAR INSTITUTE OF SCIENCE AND TECHNOLOGY**  
2010
2. **KEYNSHAM CIVIC CENTRE AND ONE STOP SHOP**  
2014
3. **LOXFORD SCHOOL OF SCIENCE AND TECHNOLOGY**  
2012








Virtual Information Modelling



Carbon Management in Design and Construction Practice



Climate Change Adaptation



Life Cycle Extension vs. replacement of Existing Building




Predicted vs Operational Performance of Buildings




TSB Metadata project

Over 20 academic papers, UKGBC, AJ100, GreenBuild, CIBSE awards recognition


# ARCHITECTURAL FEEDBACK LOOPS



Policy



Masterplan



Building



Component



Product



# RESOURCE EFFICIENT BUILDINGS

---

A **resource efficient** way of providing...



*Source: Artist Maria Arceo*

... a healthy, comfortable, safe, environment over a building's life span


# MEASURING BUILDING PERFORMANCE



Meters and submeters  
reconciled




Data logging for IEQ  
°C CO<sub>2</sub> %RH VOC



Occupier Survey  
and interviews




## DRIVERS FOR BETTER BUILDING PERFORMANCE



Climate change



Capital and  
whole life cost



Regulatory  
targets




Occupant  
experience

## REGULATORY CONTEXT



EPBD

Energy  
Performance of  
Buildings  
Directive



Energy  
Efficiency  
Directive  
NZEB

3%

EED Public stock  
refurbishment  
target



Minimum Energy  
Efficiency Target



Energy Savings  
Opportunities  
Scheme



# DISCREPANCY OF ENERGY REPORTING METRICS




# COMPARING APPLES AND PEARS...





# COMPLIANCE VS PREDICTING MEASURED ENERGY USE

---



Home


Performance gap

Evidence

What you can do

Case studies

Partners



# Get REAL about building energy consumption

Our figures show that on average, buildings consume between 1.5 and 2.5 times predicted values

CarbonBuzz will help you close the gap between calculations and actual building performance

[Get Started](#) > or [Find out more](#)



Upload

Download template to gather data



Share

Add users to your account




Compare

Compare your design estimate against




## PERFORMANCE GAP | CALCULATED VS OPERATIONAL DATA MEDIANS



# SECTOR BY SECTOR DATA | CALCULATED VS ACHIEVED PERFORMANCE


■ Calculated  
▤ Actual



**Schools**

Heat: 1.48


Electricity: 1.9



**Offices**

Heat: 1.59

Electricity: 1.71





**Universities**

Heat: 1.2

Electricity: 2.3





## ACTUAL VS DESIGN COMPARISON: QUOTIENTS




Source: Innovate UK, 2016. Building Performance Evaluation Programme: Findings from non-domestic projects, Getting the best from buildings

# INNOVATE UK CARBONBUZZ FORECAST BETA

## AHR|Aecom|CIBSE Automated tool to adjust EPCs to reflect risk factors




## EVOLVING REPORTING STANDARDS WITH MEASUREMENT AND VERIFICATION





# ENERGY DISCLOSURE LED BY NORTH AMERICAN CITIES



Philadelphia

New York City


Chicago

Seattle

San Francisco

Washington DC

Austin, Texas



Columbia university graphic



# WELL BUILDING STANDARD

---



# INVESTMENT MODELS



**Sale value**

**Developer**

Net to Gross area  
Wall to floor area  
Weight  
Buildability

**Explicit**



**Resale value**

**Owner/user**

Life cycle cost  
Energy use CO2/msq  
Building maintenance  
Lifespan  
Environmental quality

**Cumulative**



**Lifetime value**

**Government / Community**

Whole life cost  
Transport, economic and  
social infrastructure  
Landmark value  
Neighbourhood  
value

**Implicit**

1. What are the common **KPIs** reported on for new projects and refurbishments? (student survey, staff satisfaction, etc)
2. How is **building performance** currently planned for?
3. How are KPIs incorporated into **procurement**? (POE, Soft Landings, Independent Commissioning, Passivhaus, etc)




1. What are typical use/occupancy **scenarios** for different HE building types?
2. With these in mind, how much influence does a building's **architecture** have on energy use?
3. How much influence do the **users** have on energy use?
4. How are learning and research environments changing (for example in response to new funding models, new technologies, social changes, research demands etc.)
5. What **functionality** would be required in buildings to cater for this?


## RECENT RESEARCH STUDIES



**LCBA & LCBP**



# AHR INNOVATE UK BUILDING PERFORMANCE EVALUATIONS



# AHR BPE PROJECTS COMPARED TO PUBLISHED AND ANONYMISED PROJECTS

Quick More Compare

**Data to search**

☐ My data

☐ Projects shared with me

☒ Published projects

☐ Portfolios

None

☐ All

**Completion date**

min (dd/mm/yyyy) max (dd/mm/yyyy)

**Floor area**

Min Max m<sup>2</sup>

**Data quality**

All

**Building use**

Select ...

**Sector (inc):**

Education

**Type of data available**

Actual energy data

**Internal Environment**

All > % of floor area


**Data to show**

Measured By fuel


kWh/m<sup>2</sup> Performance

Display results >

Number of results = 40



Number of results = 13





# LOXFORD SCHOOL OF SCIENCE AND TECHNOLOGY

---



# ENERGY LABELS: BRUKL / EPC / DEC

## BRUKL Output Document

Compliance with England and Wales Building Regulations Part L



Project name

**Loxford School**

As designed

Date: Fri Jul 03 12:29:56 2009

### Administrative information

#### Building details

Address: Loxford Lane, Ilford, IG1 2UT

#### Certification tool

Calculation engine: Apache

Calculation engine version: "5.9.0"

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 5.9.0

BRUKL compliance check version: v3.1.a

#### Occupier details

Name: Loxford School of Science and Technology

Telephone number:

Address: Loxford Lane, Ilford, IG1 2UT

#### Certifier details

Name: Max Fordham LLP

Telephone number: 0207 267 5161

Address: 42/43 Gloucester Crescent, London, SW8 1TG

### Criterion 1: Predicted CO2 emission from proposed building does not exceed the target

1.1	Calculated CO2 emission rate from notional building	28.5 KgCO2/m2.annum
1.2	Improvement factor	0.16
1.3	LZC benchmark	0.1
1.4	Target CO2 Emission Rate (TER)	21.6 KgCO2/m2.annum
1.5	Building CO2 Emission Rate (BER)	18.5 KgCO2/m2.annum
1.6	Are emissions from building less than or equal to the target?	BER <= TER
1.7	Are as built details the same as used in BER calculations?	Separate submission

### Criterion 2: The performance of the building fabric and the building services systems should be no worse than the design limits

2.1 Are the U-values better than the design limits? Better than design limits

Element	U <sub>Limit</sub>	U <sub>Calc</sub>	U <sub>Limit</sub>	U <sub>Calc</sub>	Surface where this maximum value occurs*
Wall**	0.35	0.35	0.7	0.35	ROOM000:Surf[2]
Floor	0.25	0.25	0.7	0.25	ROOM000:Surf[0]
Roof	0.25	0.25	0.35	0.25	ROOM000:Surf[1]
Windows***, roof windows, and rooflights	2.2	2.15	3.3	2.18	ROOM001:Surf[2]
Personnel doors	2.2	0	3	0	No Personnel doors in building
Vehicle access & similar large doors	1.5	0	4	0	No Vehicle access doors in building
High usage entrance doors	6	0	6	0	No High usage entrance doors in building

U<sub>Limit</sub> = Limiting area-weighted average U-values [W/m2K]  
U<sub>Calc</sub> = Calculated area-weighted average U-values [W/m2K]  
U<sub>Limit</sub> = Limiting individual element U-values [W/m2K]  
U<sub>Calc</sub> = Calculated individual element U-values [W/m2K]

\* There might be more than one surface exceeding the limiting standards.

\*\* Automatic U-value check by the tool does not apply to curtain walls whose limiting standards are similar to those for windows.

\*\*\* Display windows and similar glazing are not required to meet the standard given in this table.

The format of this sample output document is in part from advice from Royal Institute of Building Services Officers.

## Energy Performance Certificate

Non-Domestic Building



Loxford School of Science & Technology

Loxford Lane

ILFORD

IG1 2UT

Certificate Reference Number:

0270-5964-0390-0480-0034

This certificate shows the energy rating of this building. It indicates the energy efficiency of the building fabric and the heating, ventilation, cooling and lighting systems. The rating is compared to two benchmarks for this type of building: one appropriate for new buildings and one appropriate for existing buildings. There is more advice on how to interpret this information on the Government's website [www.communities.gov.uk/epbd](http://www.communities.gov.uk/epbd).

### Energy Performance Asset Rating

More energy efficient



**A** 0-25

**B** 26-50

**C** 51-75

**D** 76-100

**E** 101-125

**F** 126-150

**G** Over 150

Less energy efficient

### Technical information

Main heating fuel: Grid Supplied Electricity  
Building environment: Heating and Natural Ventilation  
Total useful floor area (m<sup>2</sup>): 15560.369  
Building complexity (NOS level): 5  
Building emission rate (kgCO<sub>2</sub>/m<sup>2</sup>): 13.08

### Benchmarks

Buildings similar to this one could have ratings as follows:  
**46** If newly built  
**89** If typical of the existing stock

## Display Energy Certificate

How efficiently is this building being used?



Loxford School of Science & Technology

Loxford School of Science & Technology

Loxford Lane

ILFORD

IG1 2UT

Certificate Reference Number:

9503-1089-0699-0090-8495

This certificate indicates how much energy is being used to operate this building. The operational rating is based on meter readings of all the energy actually used in the building. It is compared to a benchmark that represents performance indicative of all buildings of this type. There is more advice on how to interpret this information on the Government's website [www.communities.gov.uk/epbd](http://www.communities.gov.uk/epbd).

### Energy Performance Operational Rating

This tells you how efficiently energy has been used in the building. The numbers do not represent actual units of energy consumed; they represent comparative energy efficiency. 100 would be typical for this kind of building.

More energy efficient

**A** 0-25

**B** 26-50

**C** 51-75

**D** 76-100

**E** 101-125

**F** 126-150

**G** Over 150

Less energy efficient


### Technical information

This tells you technical information about how energy is used in this building. Consumption data based on actual meter readings.  
Main heating fuel: Natural Gas  
Building Environment: Mixed-mode with Natural Ventilation  
Total useful floor area (m<sup>2</sup>): 14610  
Asset Rating: 31

	Heating	Electricity
Annual Energy Use (kWh/m <sup>2</sup> /year)	105	75
Typical Energy Use (kWh/m <sup>2</sup> /year)	155	42
Energy from renewables	0%	0%


### Total CO<sub>2</sub> Emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO<sub>2</sub>.



### Previous Operational Ratings

This tells you how efficiently energy has been used in this building over the last three accounting periods



### Administrative information

This is a Display Energy Certificate as defined in SI 2007/991 as amended.  
Assessment Software: DCLG, ORCA, v3.6.1  
Property Reference: 53964082000  
Assessor Name: Extender Buman  
Assessor Number: LCEA00050  
Accreditation Scheme: CIBSE Certification Limited  
Employer/Trading Name: Aedas Architects Ltd  
Employer/Trading Address: 5-8 Hardwick Street, London, EC1R 4RG  
Issue Date: 28-11-2011  
Notified Date: 28-11-2011  
Valid Until: 27-11-2012  
Related Party Disclosures: Not related to the occupier  
Recommendations for improving the energy efficiency of the building are contained in the accompanying Advisory Report.

BRUKL

EPC

DEC

# ENERGY END USE DATA AND CIBSE TM46 BENCHMARK



## Loxford School of Science and Technology

CarbonBuzz sector: Education

Benchmark category: Schools and seasonal public buildings

Completion date: 1/4/2010

Design data

117.2  
kWh/m<sup>2</sup>/yr

Actual data

171.6  
kWh/m<sup>2</sup>/yr



[more project details](#) +

Project Details

Documents

Users


Add New Record

CIBSE TM46 Benchmark


2012 TSB BPE Yr 2 - Main meter readings (25/3/2013)



2011 TSB BPE year 1 - Main meter readings (17/10/2012)



Building Regs As Built (17/10/2012)



RIBA



UCL

bre

AR

FeildenCleggBradleyStudios

XCO  
ENERGY




AECOM

Innovate UK

# BPE FINDINGS | VENTILATION CONTROLS

No temperature profiles, CO<sub>2</sub> triggers only – no night purge


Seasonal commissioning omitted







## BPE FINDINGS | HEATING CONTROLS

Open doors mean ground floor too cold – flow temperature increased to 70 degC – above GSHP efficiency point



## BPE FINDINGS | LIGHTING CONTROLS OMITTED ZONAL SETTINGS





# AHR BPE ACADEMIES | BUILDING PROPERTIES

**Stockport Academy**



Simple layout  
Central atrium  
Steel frame  
Cavity walls  
Full mech vent, + ch beams  
GSHP, UFH  
PIR with daylight dimming  
Part L fabric only, EPC B  
BMS  
Traditional contract

**Petchey Academy**




Simple layout  
Central atrium  
Concrete frame  
Lightweight cladding  
Full mech vent  
Cooling with HR  
PIR and absence detection  
Pre-Part L ~EPC C  
BMS  
D&B contract

**Pennywell 360 Academy**




'Village' layout  
Large internal breakout areas  
Steel frame  
Lightweight cladding & blockwork  
Mixed mode + earth ducts, biomass  
PIR & daylight dimming  
Part L fabric, EPC B  
BMS  
D&B contract

# AHR BPE FINDINGS



O&M OK but patchy on BMS  
GSHP not lead system  
AHU inverters not enabled  
CO2 sensors missing  
Faulty AHUs  
No out-of hour, half-term or holiday operation set  
Lighting controls  
High server loads  
Metering





O&M patchy  
server room and data hub rooms on the same cooling circuit as the rest of the building  
Out-of hour heating & cooling  
AHU inverters not enabled  
  
Lighting controls  
Metering





O&M patchy  
High lighting loads  
Metering  
BMS – installation, profiling, logs  
Zoning not enabled



# AHR BPE OF POOL AND TREMOUGH INNOVATION CENTRES | NZEB



# BPE FINDINGS | RECONCILIATION OF METERED AND SUBMETERED ENERGY DATA






## BPE FINDINGS | BMS CONTROL SYSTEMS COMPLEX, LACK OF LOGGING FUNCTION

Security cameras


Number plate recognition

BMS

Alarms




## PERFORMANCE GAP | COMPLEX SERVICES



**15-44% potential savings | on average £30-40K/yr/building**




# FEEDBACK ON COMFORT | RESULTS OF BUILDING USE SURVEYS




# CAPITAL AND WHOLE LIFE COST OF MECHANICAL SYSTEMS

MEP services tend to account for...

20-30% of Capital Cost



Maintenance and Energy Cost £/60 years  
Short Span Concrete + Chilled Beam + Central AHU + Curtain Wall



Over 85% of Whole life cost

Source: Aecom

**Capital cost of unused/underutilised equipment: Metering, BMS, sensors and controls, AHU inverters, actuators, LZCs, etc. can amount to 2-5% of capital cost**

**Misplaced value engineering: fabric performance and air-tightness, all openings, floor to floor heights, thermal mass, entrance lobbies, seasonal commissioning, daylighting, controls, training, manuals & log book – compliance or architecture?**

**Increased management, maintenance and energy costs: between 15-44% of total annual energy costs could be saved amounting to potentially tens of thousands of pounds per year**

**Mitigation costs: ~ 50% of annual energy costs – Soft Landings with energy disclosure approximately 0.1% of construction budget**

**Profit loss of consultants and contractors**

**Productivity loss for occupiers and FM**

**It adds up...**

## THE COST OF BUILDING PERFORMANCE EVALUATIONS

---

**50%** of our time went on gathering energy data


**20%** on chasing client, consultant and contractor teams for design vs as-built data

**25%** on analysis of the data gathered and additional energy modelling


**5%** on gathering occupant feedback



# INNOVATE UK BPE OVERALL PERFORMANCE GAP





- 30 BPE buildings with EPC data and measured performance
- Building Emission Rate (BER) does not take into account equipment load
- Fuel CO<sub>2</sub> conversion factors are also different
- Measured performance is 2-3 times the BER



- Allowance for equipment load (NCM allowance)
- Identical fuel CO<sub>2</sub> conversion factors
- Measured performance is around 50% higher than the calculated performance
- Valid if building operation broadly follows the NCM standardised operation of the respective building category



# PERFORMANCE GAP AND SEASONAL USE



Schools and seasonal buildings pose a particular problem for this type of analysis:



- The standardised profiles used in the National Calculation Methodology assume building is not in use during half-term breaks and school holidays.
- In practice buildings services across the whole building are operational even if only part of the building is used during these periods!
- This combination leads to higher performance gap compared to other building categories.

# PERFORMANCE GAP AND VENTILATION TYPE



- BPE buildings with mechanical ventilation show higher energy performance gap than naturally ventilated buildings.
- Operational risks of MV systems not fully understood and mitigated at design stages and in-operation!



# PERFORMANCE GAP AND COMPLEXITY



- Buildings that were subject to DSM analysis show higher performance gap than buildings that used SBEM!
- Does not necessary tell us which calculation method is better.
- **Buildings that used DSM are generally larger and more complex.**




# PERFORMANCE GAP AND PROCUREMENT ROUTE




- The energy performance gap in D&B procured buildings is 'slightly' higher than traditionally procured buildings.
- However, this analysis is skewed by an outlier!

1. How is the **performance gap** identified as a risk to projects?
2. What steps are being taken to improve **certainty** of performance outcomes?
3. Can capital, maintenance and mitigation **costs** be identified?
4. What else is needed to help create a **business case** for addressing the causes? (for example relationship between learning and indoor environmental quality, sector-wide benchmarking/targets etc.)

TARGETING OPERATIONAL ENERGY USE | KEYNSHAM CIVIC CENTRE & ONE STOP SHOP



# TARGETING OPERATIONAL PERFORMANCE




**CarbonBuzz.**  
an RIBA CIBSE platform

**New types of contracts are needed to enable data sharing from start to end**

## ARCHITECTURAL WINS

+

- Timber windows with 150mm acoustic louvres
- Floor to floor heights – 3.05m
- Vent voids
- Lighting: light shelves, task lighting and voids to North
- Thermal Mass incorporating cooling pipe work





# THE CHALLENGE

## PROJECT BRIEF


- Reducing council offices from 10 to 4
- Working environment with a 'one council' culture
- Halve the council's buildings energy use
- Efficient working: 688 people to 455 workstations – 3/2 desk sharing
- Targeting DEC A rating from the outset rather than BREEAM
- The first project to use BSRIA Soft Landings to achieve DEC A by 2<sup>nd</sup> year of operation



# SPATIAL CONFIGURATION

## TYPICAL OFFICE LAYOUT

- Open plan offices
- Maximise NS orientation
- Voids on North perimeter
- Voids adjacent to circulation
- Meeting rooms and kitchenettes on W perimeter
- Tea points, meeting rooms & copy areas at east & west ends



## OPENINGS

- Acoustic buffer
- Light shelves
- Night ventilation
- High level automated glazed vents





# ARCHITECTURAL DETERMINANTS

- Ventilation voids
- Visual integration of office and meeting areas
- Cross laminated timber structure
- Thermal mass in ceiling
- Good daylight penetration throughout





# 96%

Reduction in energy **££**

# 81%

GAS USE REDUCTION kWh

# 67%

ELECTRICITY USE REDUCTION kWh

# 1150m<sup>2</sup>

OF PHOTOVOLTAIC  
PANELS PROVIDE  
200,000kWh PER YEAR  
OF ELECTRICITY

# 3:2

DESK-SHARING  
RATIO WHICH  
RESULTED IN  
THE TARGET  
OF 455 WORK-  
STATIONS FOR  
**688 STAFF**

# 20%

OF THE BUILDINGS TOTAL HEATING ENERGY  
REQUIREMENT IS PROVIDED BY WATER  
COOLING SERVERS

TOTAL ANNUAL CO<sub>2</sub> EMISSIONS/m<sup>2</sup>  
(TREATED FLOOR AREA)

**36.3kgCO<sub>2</sub>/m<sup>2</sup>**

# 75%

NET TO GROSS  
INTERNAL AREA  
(OFFICES ONLY)


# PERFORMANCE CONTRACTING | ARCHITECTURE IS A KEY BENEFICIARY






## USE OF BIM TO FACILITATE FEEDBACK

---




# CLOSING THE PERFORMANCE GAP | MEASUREMENT, VERIFICATION, DISCLOSURE



**Investment KPIs**



**Virtual Information Models**



**Validation**





1. What are the barriers and incentives for energy **performance contracting** in the HE sector?
2. How can the **roles and responsibilities** of the project team be defined with building performance in mind?

## CONCLUSIONS AND NEXT STEPS

1. Future **R&D** opportunities
2. Collaborative actions between HE institutions, EAUC, AUDE & industry to build **momentum** (i.e. shared templates, reporting, anonymised benchmarking, etc.)



MAX FORDHAM



ENERGY PEOPLE BUILDINGS

# THANK YOU

